

## ORDINARY WORK PROCEDURE

### TEMPERATURE TRANSDUCE PROBE CLEANING



**CODICE: ECOPWO-005-EN-R20.0**

WRITTEN IN ENGLISH



Note: this procedure, provided free of charge, can be changed by Ecoteam at any time without giving information or disclosure, so you are asked to check and possibly download the latest version.

### ASSUMPTION:

This procedure is intended to provide information on temperature transducer probe cleaning.

It remains the obligation of the D.L. risk assessment

### FIELD OF APPLICATION

ECOCV equipment  
Temperature transducer probe cleaning [TT0x].

### CONTACT THE ASSISTANCE SERVICE

Manufacturer	Ecoteam S.p.A.
Adress	Via del Padule, 23/F 50018 Scandicci – Firenze – ITALIA
P.IVA	03984330484
Phone	+39 055 73 555
Fax	+39 055 73 55 55 00
Internet web side	<a href="http://www.ecoteam.it">www.ecoteam.it</a>
E-mail	<a href="mailto:info@ecoteam.it">info@ecoteam.it</a>
PEC	<a href="mailto:ecoteamspa@legalmail.it">ecoteamspa@legalmail.it</a>

Tabella 1 “ECOTEAM spa - info”

## REVISION LIST

Revisione	Data	Note
20.0	1/1/2020	

Tabella 2 "Revision List"

## DISTRIBUTION LIST

Name	Job	Date	Signature

Tabella 3 "Distribution list"

## SUGGESTED SPECIAL TOOLS

### Means of access

Means of access to be evaluated according to the specific situation




**TEMPERATURE TRANSDUCER PROBE CLEANING**



- |  |  |
|--|--|
| <ol style="list-style-type: none"> <li>1. Remove the probe from the housing</li> </ol>   |  |
| <ol style="list-style-type: none"> <li>2. Clean the probe with a soft cloth</li> <li>3. Check that the probe is clean and not damaged</li> <li>4. Wash the probe with demineralized water</li> <li>5. If the probe is damaged, replace it</li> </ol> |  |
| <ol style="list-style-type: none"> <li>6. Insert the probe in the specific housing.</li> </ol>   |  |

**Technical note:**

**If the replace operation is frequent, it is necessary to check the reasons.**

	<p><b>DANGER: pollution</b></p> <p>Dispose used probes according to local regulations</p>
---	---